

FIRE SAFETY SCHEDULE

Environmental Planning & Assessment Amendment Regulation 2000



Property Details

Address:

Suburb: Postcode:

Owners Details

Owners Surname: First Name:

Owners Address:

Suburb: Postcode:

Phone (h): Phone (w):

Phone (m): Fax:

Fire Safety Measures

Please tick appropriate boxes to describe the fire safety measures already installed or proposed to be installed in the building:

Existing	Proposed	Statutory Fire Safety Measures	Design & Installation	Maintenance to meet specified performance criteria
		Access Panels, Doors and Hoppers	BCA Clause C3.&AS 1530.4-2005	
		Alarm signalling Equipment	AS1670.3-2004	
		Automatic Fail Safe Devices	BCA Clause D2.21	
		Automatic Fire Detection and Alarm Systems	BCA Spec. E2.2a & AS 1670.1-2004	AS1851-2005
		Automatic Fire Suppression Systems	BCA Spec. E1.5 & AS 2118.1-1999 or AS2118.4,6-1995	AS1851-2005
		Building Occupant Warning System activated by the Sprinkler System	BCA Spec E1.5 clause 8 and/ or Clause 3.22 of AS 1670.1-2004	
		Emergency lighting	BCA Clause E4.4 & AS2293.1-2005	
		Emergency lifts	BCA Clause E3.4 & AS 1735.2-2001	Part C3.10(BCA)
		Sound system & intercom systems for emergency purposes	BCA clause E4.9 & AS 1670.4-2004 & AS 4428.4-2004	AS1851-2005

PLUS Module – Firesafety

Owner: Planning and Environment – Health, Building & Environment – Building & Compliance

DSID 1635902

Last Revised: 27/06/2018

		Emergency Evacuation Plan	AS 3745-2002	
		Exit signs	BCA Clause E4.5, E4.6 & E4.8 & AS 2293.1-2005	
		Exit Signs (non-illuminated)	BCA Clauses E4.7	
		Fire Control Centres & Rooms	BCA Spec E1.8	
		Fire Blankets	AS3504-1995 & AS 2444-2001	To meet specified performance criteria
		Fire Dampers	BCA clause C3,.15, AS 1668.1-1998 & AS 1682.1 & 2-1990	
		Fire Doors	BCA clause C3.11 and AS 1905.1-2005	AS1851-2005
		Fire Hose Reels	BCA Clause E1.4 & AS 2441-2005	
		Fire Hydrant Systems	Clause E1.3 & AS 2419.1-2005	
		Fire Seals	BCA clause C3.15 & AS 1530.4-2005	
		Fire Shutters	BCA Spec. C3.4 & AS 1905.2-2005	
		Fire Windows	BXA Spec. C3.4	
		Lightweight Construction	BCA clause C1.8 & AS 1530.3-1999	
		Mechanical Air Handling Systems	BCA Clause E2.2, AS/NZS 1668.1-1998 & AS 1668.2-1991	
		Path of Travel	EP & A Regulation clause 186	AS1851-2005
		Perimeter Vehicular Access	BCA clause C2.4	
		Portable Fire Extinguishers	BCA clause E1.6 & AS 2444-2001	AS1851-2005
		Pressurising Systems	BCA Clause E2.2 & AS/NZS 1668.1-1998	To meet specified criteria
		Required Exit Doors (power operated)	BCA Clause D2.19(d)	
		Residential Automatic Sprinkler System	AS 2118.4-1995	
		Safety Curtains in Proscenium Openings	BCA NSW Clause H101.10 or H101.10.1 as applicable	AS1851-2005
		Self-Closing Fire Hoppers	BCA clause C3.13 & AS 1530.4-2005	

PLUS Module – Firesafety

Owner: Planning and Environment – Health, Building & Environment – Building & Compliance

DSID 1635902

Last Revised: 27/06/2018

		Smoke and Heat Vents	BCA Spec. E2.2c & AS 2665-2001	
		Smoke Hazard Management Systems	BCA Part E2 & AS/NZS 1668.1-1998	
		Smoke and/or Heat Alarm systems	BCA Spec. E2.2a & AS 3486-1993	
		Smoke Dampers	AS/NZS 1668.1-1998	
		Smoke Doors	BCA Spec. C3.4	
		Solid Core Doors	BCA Clause C3.11	
		Stand-by Power Systems	BCA Clause E1.3, E3.4, E4.2 & E4.5 and AS 3000-2000	
		Wall-Wetting Sprinklers	BCA Clause C3.4 & AS 2118.2-1995	
		Warning & Operational signs	Section 183 of the EP & A Regulations 2000, AS 1905.1-2005, BCA Clause C3.6, D2.23, E3.3 & H101.8	

NOTE: The above schedule is an indicative list of existing and proposed fire safety measures relating to the subject building. The list of fire safety measures may be modified or amended prior to finalising the requirements of Council's Fire safety Order.

Lodgement of Form Options

Postal Address: City of Canada Bay Civic Centre
1A Marlborough Street, Drummoyne, NSW 2047
Locked Bag 1470 Drummoyne NSW 1470

Email: council@canadabay.nsw.gov.au
Contact: 9911 6555
Website: www.canadabay.nsw.gov.au